

**SECTION 27 13 13.13
COMMUNICATIONS COPPER CABLE SPLICING AND TERMINATIONS**

PART 1 - GENERAL

1.1 DESCRIPTION:

- A. This section specifies requirements for terminations of copper (UTP) cabling.

1.2 SUMMARY

- A. Section Includes:
1. Termination Requirements.
 2. Splicing.

1.3 REFERENCES

- A. VA Infrastructure Standard for Telecommunications Spaces.

1.4 RELATED WORK:

- A. Termination equipment: Section 27 11 19, COMMUNICATIONS TERMINATION BLOCKS AND PATCH PANELS.
- B. Copper (UTP) cabling requirements: Section 27 13 13, COMMUNICATIONS COPPER BACKBONE CABLING.
- C. Copper (UTP) cabling requirements: Section 27 15 13, COMMUNICATIONS COPPER HORIZONTAL CABLING.

1.5 SUBMITTALS:

- A. Submit in accordance with Section 27 05 00, COMMON WORK RESULTS FOR COMMUNICATIONS SYSTEMS.

PART 2 - PRODUCTS (NOT USED)

PART 3 - EXECUTION

3.1 TERMINATION REQUIREMENTS.

- A. Terminate copper (UTP) cabling used for data communications per TIA 568B.
- B. Connections shall be made to equipment certified to performance category 6a.
- C. Pre-terminated connections are required for computer room structured cabling applications. Field termination for non-computer room applications is acceptable.

3.2 SPLICING.

- A. Splicing of copper (UTP) cabling is prohibited.

- - - E N D - - -