

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO.

1. CONTRACT ID CODE

PAGE 1 OF 1 PAGES 1

2. AMENDMENT/MODIFICATION NUMBER
0003

3. EFFECTIVE DATE

4. REQUISITION/PURCHASE REQ. NUMBER

5. PROJECT NUMBER (if applicable)
666-18-1146. ISSUED BY
CODE
Department of Veterans Affairs
Network Contracting Office
NCO 19
6162 South Willow Drive, Suite 300
Greenwood Village CO 80111

36C259

7. ADMINISTERED BY (If other than Item 6)

CODE 36C259

Department of Veterans Affairs
Network Contracting Office
NCO 19
6162 South Willow Drive, Suite 300
Greenwood Village CO 80111

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code)

To all Offerors/Bidders

(X)

9A. AMENDMENT OF SOLICITATION NUMBER

36C25921R0071

9B. DATED (SEE ITEM 11)

10A. MODIFICATION OF CONTRACT/ORDER NUMBER

10B. DATED (SEE ITEM 13)

CODE

FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE

 A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b). C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: D. OTHER (Specify type of modification and authority)**E. IMPORTANT:** Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of this amendment is to answer questions that was submitted. See page 2. See page 2.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)

16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)

15B. CONTRACTOR/OFFEROR

15C. DATE SIGNED

16B. UNITED STATES OF AMERICA

16C. DATE SIGNED

(Signature of person authorized to sign)

(Signature of Contracting Officer)

Questions and Answers for Sheridan Coal Boiler Replacement and Plant Improvements

1. Does the north (2) two panel sections need removed in the MCC?

Yes, remove these for a future wall construction. Provide an approved manufacturers solution for connection and support of the east and west three phase bus bars that are currently connected and supported in the two north panel sections. Provide a new end panel/MCC cover.

2. Are Crosby (adjustable) style steam pressure safeties required. Yes.

3. Do the boiler stack economizers need pressure and temperature gauges on the inlet and outlet water connected to the control system.

Yes. Provide for new and existing boilers.

4. Does the VA want to standardize on Detroit style pressure switches?

Yes. Please use the following:

Recycle Switch (auto reset) Detroit switch inc, (Model 223 CB6 Unit 223512) close 105psig
open 125 psig Range 10 to 180 psig decreasing pressure

Non-Recycle (manual reset) Detroit switch inc, (Model 223 CB6 Unit 2231524) close 105 psig
open 125 psig Range 10 to 180 psig decreasing pressure

Header alarm/shut switches Detroit switch inc, (Model 223 CB5 Unit 2231532) close 116 psig
open 111 psig Range 5-150 psig increasing pressure

5. Does the VA require the large size control house option on the propane air mixing station? Yes.
6. How are the Baghouse trenches filled?

Fill trench with ½” gravel, compact, and provide concrete a minimum of 6” thick with two #5 rebar equally spaced in concrete.