

2. AMENDMENT/MODIFICATION NUMBER A00002	3. EFFECTIVE DATE 12-11-2018	4. REQUISITION/PURCHASE REQ. NUMBER 438-19-1-3537-0001	5. PROJECT NUMBER (if applicable) 438-18-103
--	---------------------------------	---	---

6. ISSUED BY Department of Veterans Affairs Network 23 Contracting Office (NCO 23) 111 South 18th Plaza, Suite C38 Omaha NE 68102-2077	CODE 36C263	7. ADMINISTERED BY (If other than Item 6) Department of Veterans Affairs Network 23 Contracting Office (NCO 23) 111 South 18th Plaza, Suite C38 Omaha NE 68102-2077	CODE 36C263
--	----------------	---	----------------

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders	(X)	9A. AMENDMENT OF SOLICITATION NUMBER 36C26319R0017
	<input checked="" type="checkbox"/>	9B. DATED (SEE ITEM 11) 11-08-2018
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NUMBER
		10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. December 14, 2018 at 10:00 AM CDT

12. ACCOUNTING AND APPROPRIATION DATA (If required) 438-3690162-3537-854200-3223 23NR8WA07

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
<input type="checkbox"/>	
<input type="checkbox"/>	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
<input type="checkbox"/>	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
<input type="checkbox"/>	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Project: 438-18-103, Site Prep for 2nd CT, Sioux Falls VA Medical Center, SD
VA Contracting POC: Jennifer Smith, phone: 402-995-6909, email: Jennifer.Smith19c497@va.gov

- A. The purpose of this amendment is to extend the proposal due date and post questions/answers.
- B. The proposal due date is extended from December 12, 2018 to December 14, 2018 at 10:00 AM CDT
- C. Answers to questions are provided, see attached.
- D. All terms and conditions remain unchanged.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Sharon A. Spohn NCO2315L3-0644 NCO 23 Contracting Officer
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED
	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)
	16C. DATE SIGNED

SOLICITATION QUESTIONS AND ANSWERS

#	SOW Reference	Question	Answer
1.	Lead lined sheet rock	Please verify the overall height requirement of the lead lined sheetrock.	7' - 0" above floor slab
2.	Door Leafs	Can the VA provide the height of the door frame that gets the leafed door? Also can the VA provide the weights and if both leafs need to function?	Reference plans for door schedule and details as well as door hardware specifications. Weights are manufacturer dependent.
3.	Existing carpet	Can the VA verify the existing carpet specs in Rooms A08 and A08A this is to be matched per the notes.	Basis of design: Philadelphia Commercial, Pattern: Straight Shift 54810, Color: Screw (00505); 18x36 tile, monolithic installation
4.	Schedule & Phasing	With the amount of work needed to occur in each of the phases noted on the plan, is there a possibility to extend this 120 POP. We do not believe with the structural and M/E/P work that needs to be completed in these areas that this is feasible to be completed in that small of a time frame.	No. Schedule is based on equipment delivery.
5.	Unistrut structure	Please verify the bottom of unistrut structure/elevation	Need clarification on question. If it's an existing condition, that should've been verified during site visit. For new equipment, it would be per the equipment suppliers requirement.
6.	Patient Lifts	On Drawing AC101 it states to relocate the existing patient lifts in all 3 locations. Please verify if these are to be moved by the contractor or the VA. If the contractor is responsible for moving please provide the product information on these lifts as they must be moved by brand authorized installers.	The patient lift in room A83 is indicated to remain. The patient lifts in rooms A02 and A03 indicated to be relocated by the contractor; both are Hill-Rom Likorall 250
7.	ACT	Drawing AC101 states Rooms A83 and A86 have existing ceilings in comparison to the other rooms. The finish schedule on Sheet A601 states it to get new ACT. Please verify we are not to try and reuse existing ACT in rooms A83 and A86.	Provide new ceiling grid and tile in room A83 and A86.