

VA TO IDENTIFY CIRCUITS TO BE REMOVED

PANEL NAME		LOCATION			MOUNTING SURFACE		SUPPLIED FROM			VOLTAGE			BUS		MAIN			
EBUPS-90N1										120/208V, 3PH, 4W								
CKT NO	LOAD DESCRIPTION	VA LOAD			CB			BUS			CB			VA LOAD			LOAD DESCRIPTION	CKT NO
		PH A	PH B	PH C	CODE	P	TR	A	B	C	TR	P	CODE	PH A	PH B	PH C		
1	DDC							X									EBUPS 90N2	2
3	IT ROOM 1ST							X									EBUPS 90N2	4
5	IT ROOM 1ST									X							EBUPS 90N2	6
7	VISTA IMAGING							X									EBUPS 90N3	8
9	VISTA IMAGING							X									EBUPS 90N3	10
11	VISTA IMAGING									X							EBUPS 90N3	12
13	VISTA IMAGING							X									EBUPS 90N5	14
15	VISTA IMAGING									X							EBUPS 90N5	16
17	VISTA IMAGING							X			X						EBUPS 90N5	18
19	SPARE							X									EBUPS 90N6	20
21	SPARE								X								EBUPS 90N6	22
23	SPARE								X		X						EBUPS 90N6	24
25	SPARE							X									EBUPS 10S1	26
27	SPARE								X								EBUPS 10S1	28
29	SPARE									X							EBUPS 10S1	30
31	SPARE							X									SPARE	32
33	SPARE								X								SPARE	34
35	SPARE								X		X						SPARE	36
37	EHRM RACKS							X									SPARE	38
39	EHRM RACKS								X								SPARE	40
41	EHRM RACKS									X							SPARE	42

NEL NAME		LOCATION				MOUNTING SURFACE			SUPPLIED FROM			VOLTAGE			BUS			MAIN		
EBUPS 90N2												120/208V 3PH 4W								
CKT NO	LOAD DESCRIPTION	VA LOAD				CB		BUS		CB		VA LOAD						LOAD DESCRIPTION	CKT NO	
		PH A	PH B	PH C	CODE	P	TR	A	B	C	TR	P	CODE	PH A	PH B	PH C				
1	BIO-MED - 05							X										BIO-MED - 05	2	
3	BIO-MED - 05							X										BIO-MED - 05	4	
5	BIO-MED - 05							X										BIO-MED - 05	6	
7	BIO - MED #1							X										SPARE	8	
9	BIO - MED #1							X										SPARE	10	
11	BIO - MED #1							X										SPARE	12	
13	SPARE							X										SPARE	14	
15	SPARE							X										SPARE	16	
17	SPARE							X										WIRELESS CONTROLLER	18	
19	SPARE							X										WIRELESS CONTROLLER	20	
21	SPARE							X										SPARE	22	
23	SPARE							X										SPARE	24	
25	2C-33 IRM OUTLET							X										1B-121B RCPT	26	
27	2C-33 IRM OUTLET							X										1B-121B RCPT	28	
29	SPARE							X										1B-121B RCPT	30	
31	BC-02 IRM							X										BB-92 RCPT	32	
33	BC-02 IRM							X										BB-92 RCPT	34	
35	BC-02 IRM							X										BB-92 RCPT	36	
37	BC-02 IRM RCPT							X										RESERVED FOR FUTURE	38	
39	SPARE							X										RESERVED FOR FUTURE	40	
41	SPARE							X										RESERVED FOR FUTURE	42	

PANEL NAME		LOCATION			MOUNTING SURFACE		SUPPLIED FROM			VOLTAGE		BUS		MAIN				
EBUPS 90N3										120/208V, 3PH, 4W								
CKT NO	LOAD DESCRIPTION	VA LOAD			CB		BUS			CB		VA LOAD		LOAD DESCRIPTION	CKT NO			
		PH A	PH B	PH C	CODE	P	TR	A	B	C	TR	P	CODE	PH A	PH B	PH C		NO
1	PHARMACY OPTIPILL							X						OUTLET NEWQ PROCESSOR				2
3	PHARMACY OPTIPILL								X					OUTLET NEWQ PROCESSOR				4
5	PHARMACY OPTIPILL									X				OUTLET PHARMACY				6
7	PNL EBUPS 90N4							X						DCPU				8
9	PNL EBUPS 90N4								X					DISK DRIVES				10
11	PNL EBUPS 90N4									X				OUTLET				12
13	OUTLET WIREMOLD PHARMACY							X						OUTLET VADAT DESIGNATED				14
15	OUTLET WIREMOLD OPILL								X					OUTLET MICOM				16
17	OUTLET UNDER FLOOR (TERMINAL)									X				SPARE				18
19	OUTLET UNDER FLOOR (TERMINAL)							X						20 AMP T.L				20
21	LIGHTS COMPUTER ROOM								X					20 AMP T.L				22
23	ADMIN OFFICE UTLET									X				20 AMP T.L				24
25	COMPUTER							X						SHUNT TRIP				26
27	ADMIN OFFICE UTLET								X					SHUNT TRIP				28
29	COMPUTER									X				SHUNT TRIP				30
31	SYST. D TAPE DRIVE							X						SHUNT TRIP				32
33	COMPUTER								X					SHUNT TRIP				34
35	COMPUTER									X				SHUNT TRIP				36
37	COMPUTER							X						SHUNT TRIP				38
39	COMPUTER								X					SHUNT TRIP				40
41	COMPUTER									X				SHUNT TRIP				42

PANEL NAME		LOCATION			MOUNTING SURFACE		SUPPLIED FROM			VOLTAGE			BUS	MAIN						
EBUPS 90N4										120/208V, 3PH, 4W										
CKT NO	LOAD DESCRIPTION	VA LOAD			CB		BUS			CB		VA LOAD			LOAD DESCRIPTION					CKT NO
		PH A	PH B	PH C	CODE	P	TR	A	B	C	TR	P	CODE	PH A	PH B	PH C				
1	4A-16							X										2C-90	2	
3	3051								X									B/C-02	4	
5	2A-24									X								BA-30	6	
7	2C-37							X										3C-94	8	
9	1B-47							X										4E-19	10	
11	VISTA IMG								X									1C-98	12	
13	VISTA IMG							X										1C-06	14	
15	RCPT BB-76, B/C-46								X									3C-48	16	
17	208V UNDERFLOOR VISTA IMG								X									208V UNDERFLOOR VISTA IMG	18	
19	208V UNDERFLOOR VISTA IMG							X										208V UNDERFLOOR VISTA IMG	20	
21									X										22	
23									X										24	
25								X											26	
27									X										28	
29										X									30	
31								X											32	
33									X										34	
35									X										36	
37								X											38	
39									X										40	
41									X										42	

PANEL NAME		LOCATION			MOUNTING SURFACE		SUPPLIED FROM		VOLTAGE		BUS		MAIN					
EBUPS90N5									120/208V 3PH, 4W									
CKT NO	LOAD DESCRIPTION	VA LOAD			CB		BUS			CB		VA LOAD			LOAD DESCRIPTION	CKT NO		
		PH A	PH B	PH C	CODE	P	TR	A	B	C	TR	P	CODE	PH A	PH B	PH C		
1	RCPT RM 1B-85							X									VBA	2
3	RCPT RM 1B-85, 1A-54							X									VBA	4
5	RCPT SERVER							X									VBA	6
7	RCPT SERVER							X									VBA	8
9	RCPT SERVER VISTA IMG							X									RCPT SERVER	10
11	RCPT SERVER VISTA IMG							X									RCPT SERVER	12
13	RCPT SERVER							X									RCPT SERVER	14
15	RCPT SERVER							X									RCPT SERVER	16
17	CORE SWITCHES 6509							X									RCPT SERVER	18
19	CORE SWITCHES 6509							X									RCPT SERVER	20
21	CORE SWITCHES 6509							X									RCPT SERVER	22
23	CORE SWITCHES 6509							X									RCPT SERVER	24
25	CORE SWITCHES 6509							X									RCPT SERVER	26
27	CORE SWITCHES 6509							X									RCPT SERVER	28
29	CORE SWITCHES 6509							X									RCPT 4D-02, 1A-54	30
31	CORE SWITCHES 6509							X									RCPT 4D-02	32
33	RCPT RM 2A-24							X									RCPT 4D-02	34
35	RCPT RM 2A-24							X									RCPT 2A-24	36
37	VBA							X									VBA	38
39	VBA							X									VBA	40
41	VBA							X									VBA	42