


$$1/8^* = 1'-0$$
VA FORM 08 - 6231

SEE NOTES:

1. IT IS THE RESPONSIBILITY OF CONTRACTOR TO VERIFY ALL EQUIPMENT AND REQUIRED OPENINGS SHOWN ON THE DRAWINGS MATCH WHAT IS SHOWN ON THE ACTUAL PROJECT. ANY CHANGES REQUIRED TO BE MADE IS THE CONTRACTOR'S RESPONSIBILITY TO REVERSE DRAWING. ENGINEER'S FEE DOES NOT INCLUDE PROFESSIONAL ENGINEERING FEES ASSOCIATED AND SHALL BE AT AN ADDITIONAL COST TO THE PROJECT.

KEYNOTES: #

1. INSTALL DIGITAL CAMERA SCREEN AT REMOVED WINDOW LOCATION. SEE ARCHITECTURAL DRAWINGS FOR PERFORMANCE INFORMATION. PROVIDE WITH HEADER POCKET. FROM LOCATION ABOVE OR AT HEADER POCKET, PROVIDE SURFACE MOUNTED CAMERA. PROVIDE CAMERA TO CONTROL STATION LOCATED ADJACENT TO WINDOW. PROVIDE SURFACE MOUNTED CAMERA FROM REMOVED WINDOW. PROVIDE CAMERA POCKET LOCATION UP TO CEILING SPACE. LOCATE AND MOUNT SPEAKERS IN GRID CELL AREA. PROVIDE SURFACE ENCLOSURE FOR SPEAKERS. PROVIDE TOGGLE SWITCH NEAR EVERY WINDOW TO SERVICE DISCONNECT MEANS FOR POWER TO LUMINAIRES. PROVIDE CONTROL STATION OR WALL MOUNTED AREA WINDOW LUMINAIRE IN RECEPTION AREA.

2. ELECTRICAL CONNECTION FOR HEAT TRACING IN STORM AREA. PROVIDE HEAT TRACING IN HEAT TRACE LOCATED INSIDE STORM PIPING. REFER TO PLUMBING DRAWINGS FOR EXACT LOCATION OF STORM PIPING AND HEAT TRACING BASINS. REFER TO DETAIL 3E401 FOR HEAT TRACING DETAIL.

3. PROVIDE TRIM FINISH AND COORDINATE WITH ARCHITECT AND SIZE REQUIREMENTS.

4. COORDINATE TRIM FINISH AND COORDINATE WITH ARCHITECT AND SIZE REQUIREMENTS.