


1. INSTALL 2000 Ib TENSILE STRENGTH BRAIDED POLYPROPYLENE PULL CORD IN ALL

TRENCHING AND BACKFILL ACCORDING TO SPECIFICATIONS. MINIMUM OF 4'-0" CLEAR BETWEEN ADJACENT DUCTBANKS.

4. DOWEL ENDS OF DUCTBANK TO FOUNDATION OR MANHOLE WITH A MINIMUM OF (4) #4



1. INSTALL 2000 Ib TENSILE STRENGTH BRAIDED POLYPROPYLENE


TRENCHING AND BACKFILL ACCORDING TO SPECIFICATIONS.


4. DOWEL ENDS OF DUCTBANK TO FOUNDATION OR MANHOLE WITH

3. MINIMUM OF 4'-0" CLEAR BETWEEN ADJACENT DUCTBANKS.

PULL CORD IN ALL CONDUITS.

A MINIMUM OF (4) #4 DOWELS.





3 DUCT BANK DETAIL (2x1) NO SCALE

1. INSTALL 2000 Ib TENSILE STRENGTH BRAIDED POLYPROPYLENE PULL CORD IN ALL

CONDUITS. TRENCHING AND BACKFILL ACCORDING TO SPECIFICATIONS. 3. MINIMUM OF 4'-0" CLEAR BETWEEN ADJACENT DUCTBANKS.

4. DOWEL ENDS OF DUCTBANK TO FOUNDATION OR MANHOLE WITH A MINIMUM OF (4) #4

4 DUCT BANK DETAIL (2x2) NO SCALE

1. INSTALL 2000 Ib TENSILE STRENGTH BRAIDED POLYPROPYLENE PULL CORD IN ALL CONDUITS.

TRENCHING AND BACKFILL ACCORDING TO SPECIFICATIONS. MINIMUM OF 4'-0" CLEAR BETWEEN ADJACENT DUCTBANKS. 4. DOWEL ENDS OF DUCTBANK TO FOUNDATION OR MANHOLE WITH A MINIMUM OF (4) #4 DOWELS.

		CO
Addendum 3 (AD-3)	05/20/2025	IMEG CO DRAWIN THE EXC REPROD APPROV

VA FORM 08 - 6231

ISULTANT 2882 106TH STREET
DES MOINES, IA 50322
515.334.9906 FAX: 515.334.9908
www.imegcorp.com
PROJECT # 19004249.04 SERVES PROPRIETARY RIGHTS, INCLUDING COPYRIGHTS, TO THIS THE DATA SHOWN THEREON. SAID DRAWING AND/OR DATA ARE E PROPERTY OF IMEG CORP AND SHALL NOT BE USED OR FOR ANY OTHER PROJECT WITHOUT THE EXPRESS WRITTEN
D PARTICIPATION OF IMEG CORP. REFERENCE SCALE IN INCHES

ANDERSON 13605 1st Ave. N. #100 Plymouth, MN 55441 P 763.412.4000 | F 763.412.4090 | ae-mn.com



Office of Construction and Facilities Management

U.S. Department of Veterans Affairs

NEW ELECTRICAL SITE DETAILS

Project Title Project Number 438-460 CONSTRUCT NEW SPS BID DOCUMENTS **Building Number** Drawing Number Sioux Falls, SD. $\overline{\tau}$ **FULLY SPRINKLERED** Checked Drawn KLS || AWU

Anderson Engineering of Minnesota, LLC | Proj # 16584

Drawing Title