

F

0004249.04 16584 VA Wash DC-VA Sioux Falls New SPS C.mt

VA FORM 08 - 6231

1. ALL NEW CONDUCTORS MUST BE RAN FOR ALL BRANCHES OF EMERGENCY POWER. NO SPLICING WILL BE ALLOWED.
2. ALL NEW CONDUCTORS MUST BE RAN FOR CONTROL WIRING SERVING EQUIPMENT ON EMERGENCY POWER. NO SPLICING WILL BE ALLOWED.
3. JUNCTION BOX FOR MED GAS ALARM WIRING.
4. REFER TO BLDG 24-BLDG 5 FEEDER SCHEDULE ON ES400 FOR CONDUCTOR SIZING AND QUANTITIES.

