

## Ensor, Eugene R.

---

**From:** Jason M Klocker <Jason.M.Klocker@jci.com>  
**Sent:** Wednesday, June 16, 2021 2:19 PM  
**To:** Ensor, Eugene R.  
**Subject:** [EXTERNAL] RE: Security for Modular trailers

Good afternoon Eugene,

In follow up to our conversation, please note the following solution. It turns out, we won't need the isolated security network infrastructure but rather will be able to achieve general motion detection via a wireless means only, simplifying the solution.

For each modular facility, JCI will provide three (3) area motion detectors as a wireless extension of the campus Centurion System. These signals will be transmitted to Building 66 via a wireless repeater capable of reaching the required distances. JCI will furnish the motion sensors, wireless repeater and the labor necessary to complete the installation and setup as well as the labor necessary to remove the equipment at a later date; approximately 6 months when the facilities are no longer needed. A budget for each facility is estimated at \$6,800.

Should you have any questions, please let me know.  
Thanks, Gene!

Jason Klocker  
Account Executive, Security & Fire

Johnson Controls  
3413 Gateway Blvd.  
Sioux Falls, SD 57106  
C: 605-929-7627  
F: 605-361-6773  
E: [Jason.m.klocker@jci.com](mailto:Jason.m.klocker@jci.com)



---

**From:** Ensor, Eugene R. <Eugene.Ensor@va.gov>  
**Sent:** Tuesday, June 15, 2021 1:24 PM  
**To:** Jason M Klocker <Jason.M.Klocker@jci.com>  
**Subject:** Security for Modular trailers

Jason,

Any thoughts on how to secure three (3) modular trailers? Trailers will be on campus 6 months or so for training on computers. Thanks.

Gene

## Gene R. Ensor


PM/COR 1


Facilities General Engineer

[Black Hills Health Care System, VAMC](#)

500 North 5th Street

Hot Springs, SD 57747

 605.745.2000 x 2-2541

 605.646.3007

[Eugene.Ensor@VA.Gov](mailto:Eugene.Ensor@VA.Gov)

