

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

BPA NO. 1. CONTRACT ID CODE PAGE 1 OF PAGES 4

2. AMENDMENT/MODIFICATION NUMBER A00003
 3. EFFECTIVE DATE 05-18-2017
 4. REQUISITION/PURCHASE REQ. NUMBER 438-17-3-353-0018
 5. PROJECT NUMBER (if applicable) 438-16-104

6. ISSUED BY CODE Department of Veterans Affairs
 VISN 23, Purchase and Contract Section
 4101 Woolworth Avenue, Bldg C
 Omaha NE 68105
 7. ADMINISTERED BY (If other than Item 6) CODE Department of Veterans Affairs
 VISN 23, Purchase & Contract Section
 4101 Woolworth Ave, Bldg C
 Omaha NE 68105

8. NAME AND ADDRESS OF CONTRACTOR (Number, street, county, State and ZIP Code) To all Offerors/Bidders
 9A. AMENDMENT OF SOLICITATION NUMBER (X) VA263-17-R-0160
 9B. DATED (SEE ITEM 11) X 04-20-2017
 10A. MODIFICATION OF CONTRACT/ORDER NUMBER
 10B. DATED (SEE ITEM 13)
 CODE FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or electronic communication which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or electronic communication, provided each letter or electronic communication makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. 5-23-2017 at 10:00 AM CST

12. ACCOUNTING AND APPROPRIATION DATA (If required) 438-3670162-353-854200-3220 23NRNR000

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE
 A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
 B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
 C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
 D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Project: 438-16-104, Renovate Building 5 Chapel, Sioux Falls VA Medical Center, Sioux Falls, SD
 VA Contracting POC: Sharon Spohn, phone: 402-995-4510, email: sharon.spohn@va.gov

- A. This amendment posts the question/answers and adds a stain glass specification.
- B. The questions asked thus far and the answers provided are attached.
- C. The stain glass specification is attached.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print) 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
 Sharon A. Spohn NCO2315L3-0644
 NCO23 Contracting Officer
 15B. CONTRACTOR/OFFEROR 15C. DATE SIGNED 16B. UNITED STATES OF AMERICA 16C. DATE SIGNED
 BY (Signature of Contracting Officer)

Solicitation Questions and Answers

#	SOW Reference	Question	Answer
1.	Note	There is a note about protecting equipment in offices 224-1, 221-1 in Section 01 of the specifications. What equipment is this, as we did not see these rooms on the prebid walkthrough.	No, these offices are not in Scope.
2.		Who pays for submittal exchange?	The VA. We have a separate contract for those services.
3.		Who pays for testing?	VA
4.		Is commissioning by the contractor or the owner?	Commission for Equipment is by the contractor per 019100 – General Requirements & 230800 – Mechanical Equipment.
5.		Will there be any work related to the elevator?	No
6.		Who provides the equipment and furniture in the chapel?	The VA, that is not part of this contract.
7.		What is the “A statement that pricing is in accordance with RS means pricing of 3/17/14 contract negotiated coefficient”? What does it mean, what is it for, and why is the dated 3 years behind?	This procurement is set-aside for the prime MATOC contract holders. They should know what it means. The contract was awarded on 3/17/2014 and it is a base + 4 option year contract.
8.		Will contractors be able to use elevators for personnel and materials to and from the project site?	Yes. Limit material movement shall be after 430 PM. Material and personal movement shall be limited to the two west elevators.
9.		What area is allowed for material staging?	Materials shall be stored in the contractor’s job trailers located in the southwest corner of the VA campus.
10.		Is there any required phasing to this project?	No see limited work hours – listed on sheets A102, D102 D402
11.		Do you have uninterrupted daytime work hours?	Yes, refer to question 10’s answer.
12.		Will we need to do “loud” work after VA normal working hours?	Yes, this to be discussed @ kick off meeting w/ awarded G.C.
13.		Will anyone remain working on 3 rd floor North side or will contractor have full access?	No, however partial South side will remain in operation, see D103 for construction wall.

14.	Specifications 095100	The specifications call for a square edge tile whereas the Finish and Material Legend calls for a tegular edge, please verify.	Square edge for ACT-3. Angled Tegular edge – ACT-1 and ACT-2 per A800 – Finish Legend.
15.		Also for ACT-2 what type of tile goes into the Metaphors? Are the Metaphors for 9/16” or 15/16? Suspension system?	As shown on A800 Finish Legend; Grid to be 15/16” and model 5727 that refers to Cove Coffe Style Tile for Metaphor System.
16		Can you provide the requirements for the stained glass restoration. There does not appear to be a spec section for this.	There is no formal spec section for stained glass. The spec section mentioned is included in Amendment 0003

STAINGLASS WINDOW REPAIR WORK SPECIFICATION:

Needed Repair and Restoration required for the Chapel Stained glass windows at the Sioux Falls VA Medical Center.

All Eight windows (two panels for each window) need removal and reinstallation. Size as installed currently is 3'4 3/8" wide and 5'7 13/16" high. The panels in each window overlap as installed currently.

All eight windows need old rebar supports removed and replaced. Repair additional lead locations where previous rebar had been attached.

All eight windows need cleaning.

The windows are made up using **Polish antique glass**.

Additional repairs per window by number. Left to right when entering the room:

1. No broken glass
2. No broken glass.
3. Two pieces broken on lower panel, three pieces broken on upper panel.
4. Lower panel has two broken. Painted red flash glass, one additional painted piece broken. Upper panel has one piece red flash glass chipped, needs replacing.
5. Lower panel has one broken piece.
6. No broken glass.
7. No broken glass.
8. Lower panel has one piece needing to be replaced, doesn't fit lead. Upper panel has one chipped piece and one broken piece.

The windows will be reinstalled in a different sequence.

If carpenters can enlarge the top-front of the window case, they can be reinstalled upper panel stacked on top of the lower panel